

Annexure C

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. *420/13*

Dated: *17/03/24*

It is certified that an inspection team headed by **Mr. Manish Thacker** from **Technical Manager IMC cum Incharge Chemist PHED Maintenance Sub Division No.8 Public Health Engineering Department, Indore (MP)** inspected the **Shri Devi Ahilya Shishu Vihar at Rajaswagram, Chhatribagh, Indore (MP)** on 15/03/2024 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. 101 dated 17/03/2024 of **Water Testing Laboratory, Indore (PHED Lab)** certified that the **Shri Devi Ahilya Shishu Vihar at Rajaswagram, Chhatribagh, Indore (MP)** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 16-03-2025

Signature with Seal:
Name

Manish Thacker
: ... **Mr. Manish Thacker**
Incharge Chemist
WTL M.D. No. 2 PHE/IMC
INDORE (M.P.)

To
Shri Devi Ahilya Shishu Vihar
Rajaswagram, Chhatribagh
Indore (MP)



Water Testing Laboratory
Narmada Project Campus, Musakhedi
Indore M.P. India 452001

Phone 0731-2712846 Email: ee2_narmada@rediffmail.com,
waterlabimc@outlook.com

Test Report

Customer Name and Address		Principal Shri Devi Ahiliya Shishu Vihar Rajasav Gram Chatri Bag Indore		Date of Receipt	15.03.2024	
Contact No.				Date of commencement	15.03.2024	
Received Sample Discription		Sample from RO Plant		Date of Completion	17.03.2024	
				Lab reference CH/24/101		
IS-10500-2012						
S.No.	Test	Method	Unit	Desirable Limit	Permissible Limit	Result
1	pH	IS 3025 (Part- 11): 2022	pH Scale	6.5-8.5	No Relaxation	7.05
2	Colour	IS 3025 (Part 4) Clause no. 4: 2021	Hazen Unit	5	15	0
3	Odour	IS 3025 (Part- 05): 1983	-	Agreeable	Agreeable	Agreeable
4	Taste	IS 3025 (Part - 07): 1984	-	Agreeable	Agreeable	Agreeable
5	Turbidity	IS 3025 (Part 10): 1984	NTU	1	5	0.09
6	Total Dissolved Solids	IS 3025 (Part 16): 1984	mg/l	500	2000	59
7	Total Hardness	IS 3025 (Part 21) Clause no. 5-5.7: 2009	mg/l	200	600	33.3
8	Total Alkalinity	IS 3025 (Part 23) Clause no. 4-9: 1986	mg/l	200	600	23.1
9	Nitrate	IS 3025 (Part 34) Clause no. 3.3: 1988	mg/l	45	No Relaxation	LOW
10	Free Residual Chlorine	IS 3025 (Part 26) Clause no. 5: 2021	mg/l	0.2	1	-
11	Ammonia	IS 3025 (Part - 34), Clause no. 2.D: 1988	mg/l	0.5	No Relaxation	ND
12	Fluoride	IS 3025(Part 60) Clause no. 6: 2008	mg/l	1	1.5	ND
13	Iron	IS 3025 (Part - 53), Clause no. 06: 2023	mg/l	1	No Relaxation	ND
14	Fecal Coliform Test	IS-1622:1982	CFU per 100ml	ND	ND	ND

Opinion:-

Note:-

1. The legal liabilities limited up to the analytical charges only.
2. The results are related only to the sample tested.
3. The reports shall not be reproduced except in full without approval.
4. Sample not drawn by the Laboratory.
5. The result apply to the sample as received.

Abbreviation 'ND' Not detected , 'BDL' Below Determination limit

*** End of Report ***


Authorized Signatory
Mr. Manish Thacker
Technical Manager
Chemist