

Water Testing Laboratory
Narmada Project Campus, Musakhedi
Indore M.P. India 452001

Phone 0731-2712846 Email: ee2_narmada@rediffmail.com,
waterlabimc@outlook.com

Test Report

Customer Name and Address	Shri Devi Ahilaya shishu Vihar chatribag Indore	Date of Receipt	19.05.2026
Contact No.		Date of commencement	20.05.2026
Received Sample Discription	1 ltr +250 ml R.O. Unit	Date of Completion	22.05.2026
		Lab reference DW/26/ 2903	

S.No.	Test	Method	Unit	IS-10500-2012		Result
				Desirable Limit	Permissible Limit	
1	pH	IS 3025 (Part- 11): 2022	pH Scale	6.5-8.5	No Relaxation	7.11
2	Colour	IS 3025 (Part 4): 2021	CU	5	15	0
3	Odour	IS 3025 (Part- 05): 1983	-	Agreeable	Agreeable	Agreeable
4	Taste	IS 3025 (Part - 07): 1984	-	Agreeable	Agreeable	Agreeable
5	Turbidity	IS 3025 (Part 10): 1984	NTU	1	5	0.33
6	Total Dissolved Solids	IS 3025 (Part 16): 1984	mg/l	500	2000	95
7	Total Hardness	IS 3025 (Part 21) : 2009	mg/l	200	600	66
8	Total Alkalinity	IS 3025 (Part 23): 1986	mg/l	200	600	69
9	Nitrate	IS 3025 (Part 34) : 1988	mg/l	45	No Relaxation	0.98
10	Ammonia	IS 3025 (Part - 34), 1988	mg/l	0.5	No Relaxation	0..02
11	Fluoride	IS 3025(Part 60)	mg/l	1	1.5	0.07
12	Iron	IS 3025 (Part - 53),	mg/l	1	No Relaxation	BDL
13	Fecal Coliform	IS 1622	CFU/100ml	Shlould not be detected in 100 ml		ND

Opinion:-

Note:-

1. The legal liabilities limited up to the analytical charges only.
2. The results are related only to the sample tested.
3. The reports shall not be reproduced except in full without approval.
4. Sample not drawn by the Laboratory.
5. The result apply to the sample as received.

Abbreviation 'ND' Not detected , 'BDL' Below Determination limit



*** End of Report ***

Annexure C


SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 227

Dated: 28/5/26

It is certified that an inspection team headed by **Mr. Manish Thacker** Incharge Chemist Maintenance P.H.E. Maintenance Sub division No. 8 Indore (MP) inspected the **Shri Devi Ahilaya Shishu Vihar Chatribag Indore (MP)** on 19/05/2026 and on the basis of results as per Water Test Report(Attached) bearing no DW/26/2903 dated 22/05/2026 of **Water Testing Laboratory, IMC Musakhedi Indore** certified that **Shri Devi Ahilaya Shishu Vihar Chatribag Indore (MP)** has safe drinking waterfacilities for the students and members of staff of the institution. School is also maintains thehygienic sanitation condition in the school building & the campus as per norms prescribed by theCentral/State/U.T.Govt.

This certificate is valid for 01 Year from issue.


Mr. Praveen Sharma
Assistant Engineer
Maint. Sub Dn. No. 8
PHE, INDORE (M.P.)

To
Shri Moreshwar Abhyankar Public School
Gram Dakachiya Dist. Indore (MP)